



La Puente Valley County Water District Water Meter Sizing & Flow Capacity Chart

Sizing and selection of water meters for domestic application shall be consistent with the following:

Meter Size	GPM Demand*
5/8"	1 – 20
3/4"	2 – 30
1"	3 – 50
1-1/2"	0.8 – 125
2"	1.5 – 160
3"	0.75 – 500
4"	1.5 – 1,250
6"	2 – 2,000
8"	6 – 4,000
10"	10 – 6,500
12"	12 – 8,000

*Normal Operating Range @ 100% Accuracy (+/- 1.5%)